

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Bibi Kaulan Ji Public School
Senior Secondary Near Gurdwara Tahla Sahib, Tarn Taran Road, Amritsar


No.: RWTLASR/2526/00722 Dated : 27/08/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 5088/2025 Dated: 22/08/2025

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 26/08/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar



TEST REPORT


Name & Address of Customer : Principal Bibi Kaulan Ji Public School Senior Secondary Near Gurdwara Tahla Sahib, Tarn Tarn Road, Amritsar		Customer Reference No. : Sample Submitted by : Date of Sample Receipt : Analysis Starting Date : Analysis completion Date :		No : 5088/2025 Dated : 22/08/2025 Mr. Rawaljeet Singh 26/08/2025 26/08/2025 27/08/2025	
Discipline : Chemical Testing		Group : Water			
LIR No. :	TC136022500000715F	Sample Type :	Water		
Test Report No. :	RWTLASR/2526/00722	Date of Issue :	27/08/2025		
Registration no. :	RWTLASR/REG2526/04522	Condition of Sample :	Unsealed		
Collection Point :	Private Submersible	Quantity/Type of Bottle :	1000 ml / Plastic Bottles		
Scheme/Source :	Not Mentioned(Not Mentioned)	Location/Depth :	Tahla Sahib(5/pump 350 ft) / NA		
Village :	Not Mentioned	Habitation :	Not Mentioned		
Block :	Not Mentioned	District :	Amritsar		
Latitude :	Not Mentioned	Longitude :	Not Mentioned		

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.50@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	279	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.82@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	228	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	212	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	43.28	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	25.27	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	37.98	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Amritsar

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

INVOICE

Bill No. : INV/2526/00725

Date. : 26/08/2025

To,

Principal Bibi Kaulan Ji Public School
Senior Secondary Near Gurdwara Tahla Sahib, Tarn Taran Road, Amritsar

Ref. : Letter No. 5088/2025 Dt. 22/08/2025

Sample Receiving No. RWTLASR/R2526/00725 Dt. 26/08/2025

Sr. No.	Name of Scheme / Source / Location	Nature of Sample	Category Name	Test Parameter	No. of Sample	Rate Per Parameter/ Set of Parameters	Net Amount
1	Tahla Sahib(RO UV Water)Ground Floor	Treated Water	Private Schools	Basic Chemical : Colour, Hardness, Calcium, Magnesium, Chloride, TDS, Taste, Odour, pH, Alkalinity, Turbidity	1	156.00	156.00
2	Tahla Sahib (S/pump 350 ft)	Water	Private Schools	Basic Chemical : Colour, Hardness, Calcium, Magnesium, Chloride, TDS, Taste, Odour, pH, Alkalinity, Turbidity	1	156.00	156.00
Total							312.00


Three Hundred Twelve Only.

Payment Mode : Cash

Payment Status : PAID

STR No. : 5088/2025 22/08/2025

Note:- * Discount applicable as per Government Notification Number : 987 & Date : 23/05/2025



Harinder Singh
Authorised Signatory