

REGIONAL WATER TESTING LAB, AMRITSAR
DEPARTMENT OF WATER SUPPLY & SANITATION, Punjab
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Bibi Kaulan Ji Public School
Near Gurdwara Tahla Sahib, Tarn Taran Road, Amritsar

No.: RWTLASR/2627/00925 Dated : 15/10/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 6504 Dated: 13/10/2026

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 14/10/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar

REGIONAL WATER TESTING LAB, AMRITSAR
DEPARTMENT OF WATER SUPPLY & SANITATION, Punjab
 New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
 rwtlasr1@gmail.com

TEST REPORT						
Name & Address of Customer : Principal Bibi Kaulan Ji Public School Near Gurdwara Tahla Sahib, Tarn Taran Road, Amritsar			Customer Reference No.		No : 6504 Dated : 13/10/2026	
			Sample Submitted by		Mr.Kawaljit Singh	
			Date of Sample Receipt		14/10/2026	
			Analysis Starting Date		14/10/2026	
			Analysis completion Date		15/10/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		RWTLASR/2627/00925		Date of Issue :		15/10/2026
Registration no.:		RWTLASR/REG2627/04447		Condition of Sample :		Unsealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Tarn Taran Road(S/pump 380 ft) / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Amritsar
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.69@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	Total Dissolved Solids	302	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.86@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Total Alkalinity (CaCO3)	244	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Total Hardness (CaCO3)	224	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	44.88	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	27.21	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	39.98	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results relate to the sample tested as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pardeep kumar
 Quality Manager
 Authorized Signatory
 For,Regional Water Testing Lab
 Amritsar

----- End of the Test Report -----

REGIONAL WATER TESTING LAB, AMRITSAR
DEPARTMENT OF WATER SUPPLY & SANITATION, Punjab
 New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
 rwtlasr1@gmail.com

TEST REPORT						
Name & Address of Customer : Principal Bibi Kaulan Ji Public School Near Gurdwara Tahla Sahib, Tarn Taran Road, Amritsar			Customer Reference No.		No : 6504 Dated : 13/10/2026	
			Sample Submitted by		Mr.Kawaljit Singh	
			Date of Sample Receipt		14/10/2026	
			Analysis Starting Date		14/10/2026	
			Analysis completion Date		15/10/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:			Sample Type :		Treated Water	
Test Report No.:		RWTLASR/2627/00925	Date of Issue :		15/10/2026	
Registration no.:		RWTLASR/REG2627/04448	Condition of Sample :		Unsealed	
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:		1000 ml / Transparent Plastic Bottle	
Scheme/Source:		Not Mentioned(Not Mentioned)	Location/Depth :		Tarn Taran Road(RO) / NA	
Village :		Not Mentioned	Habitation :		Not Mentioned	
Block:		Not Mentioned	District :		Amritsar	
Latitude :		Not Mentioned	Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.83@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	Total Dissolved Solids	109	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C(0.5)	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Total Alkalinity (CaCO3)	84	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Total Hardness (CaCO3)	72	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	14.42	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	8.74	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	13.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results relate to the sample tested as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

----- End of the Test Report -----